

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	3
sand & gravel	3	17
shale & sandstone streaks	17	120
rock	120	225
sandstone (St. Peter)	225	260

Total Depth **260**

Casing: 6" PVC from -2' to 56'
 4.5" PVC from 14' to 40'

Grout: BENTONITE from 0 to 55

Water from sandstone at 225' to 260'

Static level 90' below casing top which is 2' above GL

Pumping level 140' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 160' on 1/11/2012, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 100+ gpm

Owner Address: P.O. Box 632 Seneca, IL

Address of well: 792 Daisey Court Seneca, IL Seneca IL

Location source: Location from the driller

Permit Date: December 16, 2011 **Permit #:** 099-065-W11

COMPANY Rix, John Richard

FARM Van Cleave, Tom

DATE DRILLED January 6, 2012

NO. 1

ELEVATION '

COUNTY NO. 28243

LOCATION

LATITUDE 41.297950

LONGITUDE -88.617442

COUNTY LaSalle

API# 1209928243 00

26-33N-5E