

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
no record	0	456

Total Depth **456**

Casing: 20" A53 STEEL from -2' to 68'
16" A53 STEEL, WELDED from -2' to 460'

Grout: NEAT CEMENT from 0 to 68
NEAT CEMENT from 0 to 460

Water from Galesville at ' to '

Static level 153' below casing top which is 2' above GL

Pumping level 243' when pumping at 1085 gpm for 12 hr(s)

Permanent pump installed at 337' on 4/2/2013, with a capacity of 1000 gpm

Remarks: Driller's Estimated Well Yield 1,100 gpm

Owner Address: 4000 Baker Road Ottawa, IL

Address of well: 960 N 2803rd Road Utica, IL Utica IL

Location source: Location from permit

Permit Date: February 15, 2013 **Permit #:** 099-0061-W13

COMPANY Buffington, G.

FARM Unimin Corporation

DATE DRILLED April 2, 2013

NO. 2

ELEVATION '

COUNTY NO. 28301

LOCATION

LATITUDE 41.350381

LONGITUDE -88.980230

COUNTY LaSalle

API# 1209928301 00

10-33N-2E