

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	38
sand & gravel	38	53
clay	53	62
limestone	62	165
sandstone	165	180

Total Depth **180**

Casing: 5" SDRR 21 GLUE from -2' to 67'

Grout: BENTONITE from to

Water from sandstone at 165' to 180'

Static level 10' below casing top which is 2' above GL

Pumping level 12' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 60' on 11/10/2023, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 3991 E 9th Rd Mendota, IL

Address of well: 209 Mechanic St Troy Grove, IL Troy Grove IL

Location source: Global Positioning System verified

Permit Date: September 20, 2023 **Permit #:** 099-044-23

COMPANY Dober, Darrel

FARM Gonzalez, Maribel

DATE DRILLED October 13, 2023 **NO.** 1

ELEVATION ' **COUNTY NO.** 29265

LOCATION

LATITUDE 41.467683 **LONGITUDE** -89.081983

COUNTY LaSalle **API#** 1209929265 00 **35-35N-1E**