

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	16
sand & gravel	16	25
clay w/streaks of gravel	25	130
sandstone w/ streaks of lime	130	155
limestone	155	200
clean sandstone	200	220

Total Depth **220**

Casing: 6" PVC SDR 21 from -1' to 144'

Grout: BENTONITE from 0 to 120

Water from sandstone at 200' to 220'

Static level 30' below casing top which is 1' above GL

Pumping level 60' when pumping at 22 gpm for 1 hr(s)

Permanent pump installed at 120' on 11/30/2023, with a capacity of 22 gpm

Owner Address: 8011 Walker Rd Yorkville, IL

Address of well: 4052 E 1950th Rd Sheridan, IL Sheridan IL

Location source: Global Positioning System verified

Permit Date: November 1, 2023

Permit #: 099-051-2023

COMPANY K & K Well Drilling, Inc

FARM Bell, Quentin

DATE DRILLED November 16, 2023

NO.

ELEVATION '

COUNTY NO. 29267

LOCATION

LATITUDE 41.520833

LONGITUDE -88.797222

COUNTY LaSalle

API# 1209929267 00

8-35N-4E