

# ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

| Water Well                             | Top | Bottom |
|----------------------------------------|-----|--------|
| clay                                   | 0   | 3      |
| sand & gravel w/ little clay           | 3   | 18     |
| shale w/ coal                          | 18  | 80     |
| sandstone                              | 80  | 200    |
| transitional limestone/shale/sandstone | 200 | 225    |
| limestone                              | 225 | 370    |
| sandstone                              | 370 | 400    |
| not listed                             | 400 | 460    |

**Total Depth** **460**

Casing: 5" pvc glued sdr 21 from -1' to 159'  
5" pvc glued sdr 17 from 159' to 239'

Grout: BENTONITE from 0 to 239

Water from sandstone at 370' to 420'

Static level 100' below casing top which is 1' above GL

Pumping level 105' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 140' on 3/15/2024, with a capacity of 10 gpm

Remarks:

Owner Address: 2920 E 15th Rd Ottawa, IL

Address of well: 2920 E 15th Rd Ottawa IL

Add'l loc info: Lot: Subdivision:

Location source: Global Positioning System verified

**Permit Date:** October 19, 2023

**Permit #:** 099-047-2023

**COMPANY** Strange, Michael

**FARM** Golaszeski, Dave & Cathy

**DATE DRILLED** March 11, 2024

**NO.** 2

**ELEVATION** '

**COUNTY NO.** 29283

**LOCATION**

**LATITUDE** 41.357150

**LONGITUDE** -88.866017

**COUNTY** LaSalle

**API#** 1209929283 00

**3-33N-3E**