

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	18
stiff sandy clay	18	26
soft brown sandstone	26	34
sandy shale	34	40
sandy limestone	40	44
shale	44	48
sandy shale	48	86
hard gray sandy shale	86	94
sandy shale	94	97
hard gray sandy shale	97	131
clean sand	131	180

Total Depth **180**

Casing: 5" PVC SDR 26 from 1' to 130'

Grout: BENSEAL from 3 to 130

Pumping level ' when pumping at 25 gpm for hr(s)

Remarks: Drillers Estimated Well Yield 25 gpm

Owner Address: 9789 Sand Barrens Lane St. Francisville, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: May 5, 2020

Permit #: 101-0006-2020

COMPANY Speth, James

FARM Johnson, Wayne

DATE DRILLED May 27, 2020

NO.

ELEVATION '

COUNTY NO. 33099

LOCATION

LATITUDE 38.590556

LONGITUDE -87.737222

COUNTY Lawrence

API# 1210133099 00

22-2N-12W