

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
medium to coarse sand	1	35
embedded clay	35	45
coarse gravel	45	55
sandy clay	55	60
coarse sand	60	63
fine to medium sand	63	75
coarse sand at	75	75

Total Depth

75

Casing: 14" PLAIN STEEL from 0' to 55'

12" SS SCREEN from 55' to 75'

Screen: 20' of 1" diameter 0.05 slot

Grout: BENTONITE from 0 to 20

Static level 9' below casing top which is 0' above GL

Pumping level 60' when pumping at 1100 gpm for 0 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: 1018 Hahanman Rd. Rock Falls, IL

Location source: Location from permit

Permit Date: November 15, 1993 **Permit #:** 023568

COMPANY Klassen, Genevieve "Sue"

FARM Droege, Phillip

DATE DRILLED May 11, 1994

NO.

ELEVATION 0'

COUNTY NO. 22034

LOCATION

LATITUDE 41.732145

LONGITUDE -89.628240

COUNTY Lee

API# 1210322034 00

7-20N-8E