

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	4
brown clay with stones	4	25
gray clay with stones	25	365
brown sandstone & lime soft & hard	365	430
white sandstone	430	460

Total Depth **460**

Casing: 5" A53 T&C from -1' to 440'

Grout: BENTONITE 20% from 0 to 440

Water from sandstone at 440' to 460'

Static level 263' below casing top which is 1' above GL

Pumping level 300' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 325' on 12/21/2001, with a capacity of 10 gpm

Remarks: driller's est. well yield 40 gpm

Owner Address: 1127 First St. Batavia, IL

Address of well: West Brooklyn Rd. Compton, IL Compton IL

Add'l loc info: Lot: 2 Subdivision:

Location source: Location from permit

Permit Date: September 25, 2001 **Permit #:**

COMPANY Pitz, John W.

FARM Eckblade, Richard

DATE DRILLED December 4, 2001 **NO.**

ELEVATION 0' **COUNTY NO.** 23185

LOCATION

LATITUDE 41.698901 **LONGITUDE** -89.092624

COUNTY Lee **API#** 1210323185 00 **10-37N-1E**