

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	6
sand gravel	6	52
clay	52	60
limestone	60	205

Total Depth **205**

Casing: 6" PLASTIC from 0' to 71'

Grout: BENTONITE from 0 to 71

Water from rock at 95' to 205'

Static level 95' below casing top which is 2' above GL

Pumping level 140' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 140' on 10/18/2006, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 60 gpm

Owner Address: 1569 Nelson Rd. Dixon, IL

Address of well: same as above

Location source: Location from permit

Permit Date: September 28, 2006 **Permit #:** 103-060-06

COMPANY Dana, Steve

FARM Stewart, Doug

DATE DRILLED October 11, 2006 **NO.**

ELEVATION 664' **COUNTY NO.** 23790

LOCATION

LATITUDE 41.808683 **LONGITUDE** -89.572067

COUNTY Lee **API#** 1210323790 00 **15-21N-8E**