

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	22
yellow limestone	22	130
gray limestone	130	190

Total Depth **190**

Casing: 6" PVC from 0' to 40'

Grout: BENTONITE from 0 to 40

Water from rock at 100' to 190'

Static level 100' below casing top which is 2' above GL

Pumping level 160' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 160' on 9/23/2009, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 504 N. Galena Ave Dixon, IL

Address of well: 705 Heights Rd Dixon, IL Dixon IL

Add'l loc info: Lot: 2 Subdivision: Lowell Heights

Location source: Location from permit

Permit Date: June 11, 2009

Permit #: 103-019-09

COMPANY Dana, Steven William

FARM Arrellano, Lee & Jamie

DATE DRILLED September 19, 2009

NO.

ELEVATION '

COUNTY NO. 23984

LOCATION

LATITUDE 41.879028

LONGITUDE -89.494083

COUNTY Lee

API# 1210323984 00

20-22N-9E