

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
tan clay	0	7
gravel w/ clay	7	12
tan clay	12	19
tan limestone	19	78
gray limestone	78	137
fractured tan limestone	137	142
gray limestone	142	224
sandstone w/ green shale	224	237
sandstone	237	315

Total Depth **315**

Casing: 5" pvc sdr 21 from 0' to 180'

Grout: BENTONITE from 0 to 180

Water from rock at 180' to 315'

Static level 55' below casing top which is 2' above GL

Pumping level 75' when pumping at 30 gpm for 1 hr(s)

Permanent pump installed at 125' on 6/11/2024, with a capacity of 10 gpm

Remarks:

Owner Address: 1944 Plum Hollow Ct Dixon, IL

Address of well: 1944 Plum Hollow Ct Dixon IL

Add'l loc info: Lot: Subdivision:

Location source: Global Positioning System verified

Permit Date: June 3, 2024

Permit #: 103-020-24

COMPANY Albrecht, Harold Dean

FARM Thomas, Gregory

DATE DRILLED June 7, 2024

NO. 6089

ELEVATION '

COUNTY NO. 24519

LOCATION

LATITUDE 41.864000

LONGITUDE -89.509000

COUNTY Lee

API# 1210324519 00

30-22N-9E