

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	4
yellow clay	4	17
soft blue clay	17	102
coarse gray sand	102	114

Total Depth **114**

Casing: 5" PVC SDR21 from -2' to 106'

3" STAINLESS STL SCREEN from 106' to 114'

Screen: 8' of 3" diameter 10 slot

Grout: BENTONITE from to

Water from sand at 102' to 114'

Static level 64' below casing top which is 2' above GL

Pumping level 84' when pumping at 40 gpm for 2 hr(s)

Permanent pump installed at 110' on 12/22/2008, with a capacity of 40 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 29695E 100N Strawn, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 20, 2008

Permit #: 105-1066-2008

COMPANY Kingsley, Arthur W.

FARM Kilgus, Denise

DATE DRILLED December 22, 2008

NO.

ELEVATION '

COUNTY NO. 23613

LOCATION

LATITUDE 40.632654

LONGITUDE -88.355753

COUNTY Livingston

API# 1210523613 00

12-25N-7E