

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
gray clay & gravel	2	28
sand & gravel	28	37

Total Depth

37

Casing: 5" SDR 21 from -3' to 33'

5" SCREEN/SS from 33' to 37'

Screen: 4' of 5" diameter 20 slot

Grout: BENTONITE from 0 to 23

Water from sand & gravel at 28' to 37'

Static level 14' below casing top which is 3' above GL

Pumping level 20' when pumping at 30 gpm for hr(s)

Permanent pump installed at 25' on 6/27/2023, with a capacity of 7 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 27500 E 200 North Rd Strawn, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: June 9, 2023

Permit #: 105-1455-2023

COMPANY Kickapoo Drilling Co.

FARM Monahan, Mike

DATE DRILLED June 27, 2023

NO. 2

ELEVATION '

COUNTY NO. 23985

LOCATION

LATITUDE 40.645615

LONGITUDE -88.398603

COUNTY Livingston

API# 1210523985 00

10-25N-7E