

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	41
blue clay	41	59
sand	59	62
blue clay	62	70
white sand	70	88

Total Depth

88

Casing: 6" PVC SDR 21 from -1' to 60'

4.5" PVC SCH 40 from 57' to 83'

4.5" PVC SCREEN from 83' to 88'

Screen: 5' of 4.5" diameter 0.015 slot

Grout: BENSEAL from 0 to 60

NATURAL from 70 to 88

Water from sand at 83' to 88'

Static level 60' below casing top which is 1' above GL

Pumping level 75' when pumping at 5 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 7 gpm

Owner Address: 403 Colegrove St. Assumption, IL

Address of well: 12795 N. 1050th Rd. Macomb, IL Macomb IL

Location source: Location from permit

Permit Date: August 22, 2006

Permit #: 109-09-06

COMPANY Joseph Allen

FARM Weston, Bill

DATE DRILLED October 3, 2006

NO.

ELEVATION '

COUNTY NO. 22973

LOCATION

LATITUDE 40.432295

LONGITUDE -90.660199

COUNTY McDonough

API# 1210922973 00

7-5N-2W