

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	24
sand	24	42
shale	42	61
limestone	61	64
shale	64	80
limestone	80	110
shale	110	182
limestone	182	295

Total Depth **295**

Casing: 6" PVC from -1' to 62'

4.5" PVC from 55' to 195'

4.5" PVC from 195' to 295'

Screen: 100' of 4.5" diameter 0.25 slot

Grout: BENTONITE from 0 to 62

BENTONITE from 55 to 195

Water from limestone at 220' to 295'

Static level 128' below casing top which is 1' above GL

Pumping level 220' when pumping at 12 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 12 gpm

Owner Address: 3850 Ohio Ave. St. Charles, IL

Address of well: 7xx N 1200th Rd. (TBA) Colchester, IL Colchester
IL

Location source: Location from permit

Permit Date: November 20, 2006

Permit #: 109-17-06

COMPANY Corwin Gingerich

FARM Bullock, Ron

DATE DRILLED May 9, 2007

NO.

ELEVATION '

COUNTY NO. 22982

LOCATION

LATITUDE 40.455833

LONGITUDE -90.760556

COUNTY McDonough

API# 1210922982 00

5-5N-3W