

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	51
limestone	51	100

Total Depth **100**

Casing: 6" BLACK STEEL from 0' to 51'

Size hole below casing: 6"

Water from limestone at 51' to 100'

Static level 40' below casing top which is 1' above GL

Pumping level 50' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Driller's Log filed.

Address of well: 24017 Ken Dr. Harvard, IL Harvard IL

Location source: Digital Orthophoto Quad

Verified by: VJA on 8/12/2009

Permit Date: December 14, 1971 **Permit #:** 15965

COMPANY Bloyer, Ralph

FARM Vermett, Larry

DATE DRILLED June 8, 1972

NO. 1

ELEVATION '

COUNTY NO. 01363

LOCATION

LATITUDE 42.413571

LONGITUDE -88.666684

COUNTY McHenry

API# 1211101363 00

4-45N-5E