

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
sand	5	25
clay	25	100
shale & rock	100	196
limestone	196	295

Total Depth

295

Casing: 5" BLACK STEEL 15#/FT from 0' to 196'

Grout: CUTTINGS from 0 to 196

Size hole below casing: 5"

Water from limestone at 197' to 295'

Static level 140' below casing top which is 1' above GL

Pumping level 140' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 240' on 2/22/1979, with a capacity of 15 gpm

Remarks: owner installed own tank

Owner Address: Dean St. Woodstock, IL

Location source: Field verified

Verified by: VJA on 7/29/2010

Permit Date: November 6, 1978

Permit #: 81645

COMPANY Barker, Paul A.

FARM Ragusin, David

DATE DRILLED February 22, 1979

NO.

ELEVATION '

COUNTY NO. 27739

LOCATION 2000'S line, 1600'W line of

LATITUDE 42.260443

LONGITUDE -88.446891

COUNTY McHenry

API# 1211127739 00

29-44N-7E