

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand	0	10
clay	10	52
sand	52	73
clay	73	94
water-gravel	94	98

Total Depth

98

Casing: 5" 15# STL T&C ASTM A53 from 0' to 98'

Grout: CLAY SLURRY from 0 to 20

Size hole below casing: 5"

Water from gravel at 94' to 98'

Static level 40' below casing top which is 1' above GL

Pumping level 45' when pumping at gpm for 4 hr(s)

Permanent pump installed at 45' on 5/17/1993, with a capacity of 12 gpm

Owner Address: 805 Napa St. Carol Stream, IL

Address of well: 2514 Hidden Trail Spring Grove, IL Spring Grove IL

Add'l loc info: Lot: 73 Subdivision: Pine Meadows

Location source: Aerial Photograph verified

Verified by: VJA on 9/13/2011

Permit Date: September 28, 1992

Permit #: 111-F5242

COMPANY Elfmann, Larry T.

FARM Tijerina, Roy Construction

DATE DRILLED May 17, 1993

NO.

ELEVATION

COUNTY NO. 33009

LOCATION

LATITUDE 42.456206

LONGITUDE -88.246597

COUNTY McHenry

API# 1211133009 00

24-46N-8E