

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	23
sand	23	45
sand & gravel	45	60

Total Depth

60

Casing: 5" SDR 21 200# PVC from 0' to 57'

4" SCREEN PKG from 54' to 60'

Screen: 3' of 4" diameter 20 slot

Grout: SLURRY from 0 to 57

Size hole below casing: 4"

Water from drift at 57' to 60'

Static level 25' below casing top which is ' above GL

Pumping level 40' when pumping at gpm for 24 hr(s)

Permanent pump installed at 40' on 8/6/1994, with a capacity of 18 gpm

Owner Address: 325 Circle Dr. Algonquin, IL

Address of well: 6204 Smith Rd. Crystal Lake, IL. Crystal Lake IL

Add'l loc info: Lot: 35 Subdivision: Steeple Run

Location source: Aerial Photograph verified

Verified by: VJA on 4/13/2012

Permit Date: January 18, 1994

Permit #: 111-F7756-94

COMPANY Hutchings, Clyde A.

FARM Martinez, Carlos

DATE DRILLED July 11, 1994

NO.

ELEVATION 885' GL

COUNTY NO. 33287

LOCATION

LATITUDE 42.239617

LONGITUDE -88.276648

COUNTY McHenry

API# 1211133287 00

2-43N-8E