

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	80
gray clay	80	120
gray sand	120	125
gray clay	125	160
gray sand & gravel	160	170

Total Depth **170**

Casing: 5" 15# BLACK from 0' to 166'

Screen: 5' of 4" diameter 20 slot

Grout: DRL CUTTINGS from 0 to 170

Size hole below casing: 4"

Water from sand & gravel at 166' to 170'

Static level 100' below casing top which is 1' above GL

Pumping level 110' when pumping at gpm for 2 hr(s)

Permanent pump installed at 140' on 10/25/1994, with a capacity of 10 gpm

Owner Address: 408F St Johns Woodstock, IL

Address of well: 15013 Countryside Lane Harvard, IL Harvard IL

Add'l loc info: Lot: 2 Subdivision: Countryside Acres

Location source: Aerial Photograph verified

Verified by: VJA on 12/23/2009

Permit Date: June 3, 1994

Permit #: 111-F8645-94

COMPANY Adkins, Phillip G.

FARM Austin, Jeff & Linda

DATE DRILLED October 20, 1994

NO.

ELEVATION '

COUNTY NO. 33472

LOCATION

LATITUDE 42.399257

LONGITUDE -88.563122

COUNTY McHenry

API# 1211133472 00

8-45N-6E