

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	15
gray sandy clay	15	60
sand & gravel	60	65

Total Depth **65**

Casing: 5" GALV. 15#/FT. from -1' to 65'

Water from sand & gravel at 60' to 65'

Static level 6' below casing top which is 1' above GL

Pumping level 12' when pumping at 15 gpm for 48 hr(s)

Permanent pump installed at 20' on 10/1/1995, with a capacity of 10 gpm

Owner Address: c/o R. Scott Lindemann 10702 Allendale Road
Woodstock, IL

Address of well: 10806 Allendale Road Woodstock, IL Woodstock IL

Location source: Tax record verified

Verified by: VJA on 2/4/2010

Permit Date: October 31, 1994 **Permit #:** 111-F-9825-94

COMPANY Mattson, Arthur R.

FARM Timber Creek Nursery

DATE DRILLED September 30, 1995 **NO.**

ELEVATION ' **COUNTY NO.** 34196

LOCATION

LATITUDE 42.400517 **LONGITUDE** -88.408562

COUNTY McHenry **API#** 1211134196 00 **3-45N-7E**