

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well, Plugged	Top	Bottom
topsoil	0	2
clay	2	20
gravel	20	35
clay	35	154
gravel	154	160

Total Depth **160**

Casing: 5" PVC ASTM F480 15#/FT from 0' to 155'

Screen: 5' of 5" diameter 25 slot

Grout: PRESSURE from 0 to 155

Water from gravel at 154' to 160'

Static level 70' below casing top which is 1' above GL

Pumping level 140' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at ' on 9/8/1997, with a capacity of gpm

Owner Address: 5515 W. Lakeshore Dr. Wonder Lake, IL

Address of well: 8016 Balsam Wonder Lake, IL Wonder Lake IL

Add'l loc info: Lot: 2, 3, 4 Subdivision: Wonderview

Location source: Aerial Photograph verified

Verified by: VJA on 6/17/2011

Permit Date: June 9, 1997

Permit #: 111-G-5792-97

COMPANY Nice, Marvin R.

FARM Blaschak Construction

DATE DRILLED September 2, 1997

NO.

ELEVATION '

COUNTY NO. 35183

LOCATION

LATITUDE 42.370767

LONGITUDE -88.354778

COUNTY McHenry

API# 1211135183 00

19-45N-8E