

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
clay	2	195
gravel & clay	195	210
clay	210	223
limestone	223	240

Total Depth **240**

Casing: 5" PVC/ASTM F480 from 0' to 202'

5" STL/ASTM A53B 15#/FT from 202' to 223'

Grout: PRESSURE from 0 to 223

Water from limestone at 223' to 240'

Static level 60' below casing top which is 1' above GL

Pumping level 180' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at ' on 10/17/1997, with a capacity of gpm

Owner Address: 6206 Crescent Dr. Huntley, IL

Address of well: 16009 Lerita Dr. Union, IL Union IL

Add'l loc info: Lot: 46 Subdivision: Parkside Crossing

Location source: Aerial Photograph verified

Verified by: VJA on 8/26/2010

Permit Date: July 6, 1997

Permit #: G6091

COMPANY Nice, Marvin R.

FARM Berryhill, David & Janet

DATE DRILLED October 14, 1997

NO.

ELEVATION '

COUNTY NO. 35257

LOCATION

LATITUDE 42.175828

LONGITUDE -88.510337

COUNTY McHenry

API# 1211135257 00

26-43N-6E