

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay & gravel	0	93
sand & gravel	93	97

Total Depth **97**

Casing: 5" 200# PVC from 0' to 93'

5" STAINLESS STL SCREEN from 93' to 97'

Screen: 4' of 5" diameter 20 slot

Grout: BENTONITE from 0 to 80

Static level 23' below casing top which is 1' above GL

Pumping level 34' when pumping at 12 gpm for 9 hr(s)

Permanent pump installed at 60' on 6/15/2006, with a capacity of 10 gpm

Remarks: driller's est. well yield 15 gpm

Owner Address: 9907 Lilja Rd. Harvard, IL

Address of well: same as above

Location source: Digital Orthophoto Quad

Verified by: VJA on 7/14/2009

Permit Date: July 25, 2005

Permit #: 111-0625-05

COMPANY Hoover Water Well Service

FARM Hansen, Dan

DATE DRILLED June 5, 2006

NO.

ELEVATION '

COUNTY NO. 42839

LOCATION

LATITUDE 42.470426

LONGITUDE -88.649017

COUNTY McHenry

API# 1211142839 00

16-46N-5E