

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
sand & gravel	1	60

Total Depth **60**

Casing: 5" STEEL ASTM 53B from -1' to 56'

4" PVC SCREEN from 56' to 60'

Screen: 4' of 4" diameter 15 slot

Grout: BENSEAL from to

Water from sand & gravel at 56' to 60'

Static level 3' below casing top which is 1' above GL

Pumping level 38' when pumping at 28 gpm for 2 hr(s)

Permanent pump installed at 40' on 10/2/2008, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 16502 Garden Valley Woodstock, IL

Address of well: same as above

Location source: Aerial Photograph verified

Verified by: VJA on 11/30/2012

Permit Date: September 10, 2008 **Permit #:** 111-0374-08

COMPANY Martin, C. & Sons Well Co.

FARM Tengler, Billie Jo

DATE DRILLED October 2, 2008

NO.

ELEVATION '

COUNTY NO. 43678

LOCATION

LATITUDE 42.273904

LONGITUDE -88.515985

COUNTY McHenry

API# 1211143678 00

22-44N-6E