

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
red clay	0	26
gray clay	26	55
clay w/ gravel	55	79
gravel	79	84
yellow gravel	81	91

Total Depth

91

Casing: 5" pvc sdr 21 from -2' to 87'

5" screen from 87' to 91'

Screen: 4' of 5" diameter 20 slot

Grout: 20% BENTONITE from 0 to 80

Water from gravel at 87' to 91'

Pumping level 20' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 132' on 4/19/2024, with a capacity of 15 gpm

Remarks:

Owner Address: PO Box 367 Spring Grove, IL

Address of well: 3319 East Solar Mills Rd Spring Grove IL

Add'l loc info: Lot: Subdivision:

Location source: Global Positioning System verified

Verified by: VJA on 12/1/2024

Permit Date: April 4, 2024

Permit #: 111-24-069-24

COMPANY Binz, David Joseph

FARM Reid, Lee

DATE DRILLED April 12, 2024

NO.

ELEVATION

'

COUNTY NO. 46710

LOCATION

LATITUDE 42.443889

LONGITUDE -88.263056

COUNTY McHenry

API# 1211146710 00

26-46N-8E