

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black topsoil	0	3
yellow clay	3	12
gray clay	12	35
coarse gray sand & gravel	35	45
gray clay	45	55

Total Depth

55

Casing: 4" PVC from -2' to 40'

4" PVC SCREEN from 40' to 45'

Screen: 5' of 4" diameter 20 slot

Grout: EASY SEAL from 0 to 30

BIRDSEED SAND from 30 to 45

Water from sand at 35' to 45'

Static level 18' below casing top which is 2' above GL

Pumping level 18' when pumping at 25 gpm for 3 hr(s)

Permanent pump installed at 36' on 2/21/2017, with a capacity of 5 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 17249 E. 3150 N. Rd. Gridley, IL

Address of well: same as above

Location source: Location from permit

Permit Date: September 19, 2016

Permit #: 113-06516

COMPANY Smith, David M.

FARM Carr, Julie

DATE DRILLED January 30, 2017

NO.

ELEVATION '

COUNTY NO. 25116

LOCATION

LATITUDE 40.744998

LONGITUDE -88.942453

COUNTY McLean

API# 1211325116 00

1-26N-2E