

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
tan clay	2	13
gray clay	13	167
peat	167	176
gray clay	176	306
sand	306	440

Total Depth **440**

Casing: 5" STEEL from -3' to 430'

5" SCREEN/SS from 430' to 440'

Screen: 10' of 5" diameter 20 slot

Grout: BENTONITE from 0 to 420

Water from sand at 306' to 440'

Static level 285' below casing top which is 2' above GL

Pumping level ' when pumping at 50 gpm for hr(s)

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 4528 E 1625 N Rd Danvers, IL

Address of well: same as above

Location source: Location from the driller

Permit Date: May 2, 2023

Permit #: 113-015-23

COMPANY Kickapoo Drilling Co.

FARM Evergreen FS

DATE DRILLED May 31, 2023

NO. 2

ELEVATION '

COUNTY NO. 25456

LOCATION

LATITUDE 40.522133

LONGITUDE -89.180953

COUNTY McLean

API# 1211325456 00

23-24N-1W