

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown till	0	15
limestone	15	23
brown shale	23	27
gray shale	27	34
gray sandstone	34	51
gray shale, fractures at 53' - 55'	51	80

Total Depth

80

Casing: 6" SDR 21 PVC from -1' to 15'
 30" FIBERGLASS from 15' to 80'

Grout: BENTONITE CHIPS from 13 to 14
 BUCKSHOT 1/4" from 14 to 80

Water from gray shale at 53' to 55'

Remarks: Driller's Estimated Well Yield .5 gpm

Owner Address: 3113 Cedar Hill Dr. Chillicothe, IL

Address of well: 1005 Willow Rd. Sparland, IL Sparland IL

Location source: Location from permit

Permit Date: August 1, 2011

Permit #: 123-08-11

COMPANY Wiesenhofer, Donald E.

FARM Fidler, Phyllis

DATE DRILLED August 17, 2011

NO.

ELEVATION '

COUNTY NO. 21086

LOCATION

LATITUDE 41.019737

LONGITUDE -89.445907

COUNTY Marshall

API# 1212321086 00

14-12N-9E