

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand fine	0	35
sand fine to med w/ fine gravel	35	60
sand med w/ med gravel	60	79
sand med w/ fine gravel	79	87
sand med w/ med gravel	87	93

Total Depth

93

Casing: 5" PVC SDR 21 from -2' to 87'

5" SCREEN from 87' to 93'

Screen: 4' of 5" diameter 20 slot

Grout: BENSEAL from 0 to 81

Water from sand/gravel at 27' to 93'

Static level 27' below casing top which is 2' above GL

Pumping level 30' when pumping at 35 gpm for 1 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 35 gpm

Owner Address: 10253 N County Rd 1400 E Bath, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: May 23, 2024

Permit #: 125-033-2024

COMPANY Wagenbach, Mark

FARM Galla, James & Kylie

DATE DRILLED June 12, 2024

NO. 1

ELEVATION '

COUNTY NO. 23388

LOCATION

LATITUDE 40.209000

LONGITUDE -90.087639

COUNTY Mason

API# 1212523388 00

2-20N-9W