

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	2
sand fine to med	2	9
sand fine to coarse	9	40
clay silty soft gray	40	47
sand fine to med	47	51
sand med to coarse w/ fine gravel	51	63

Total Depth

63

Casing: 5" PVC SDR 21 from -2' to 71'

5" SCREEN from 59' to 63'

Screen: 4' of 5" diameter 20 slot

Grout: BENSEAL from 0 to 51

Water from sand/gravel at 27' to 63'

Static level 27' below casing top which is 2' above GL

Pumping level 33' when pumping at 30 gpm for 2 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 25637 Levee St Greenvview, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: September 11, 2023

Permit #: 129-007-2023

COMPANY Greenfield, Edward K.

FARM Dirks, Harold

DATE DRILLED September 29, 2023

NO. 2

ELEVATION '

COUNTY NO. 21873

LOCATION

LATITUDE 40.137806

LONGITUDE -89.677417

COUNTY Menard

API# 1212921873 00

33-20N-5W