

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	18
fine sand	18	28
embedded clay/sand	28	60
gray clay	60	70
fine med	70	88
fine coarse sand w/ gravel	88	158

Total Depth

158

Casing: 12" STEEL from 0' to 136'

12" SCREEN from 136' to 156'

Screen: 20' of 12" diameter 0.08 slot

Grout: NEAT CEMENT from 8 to 28

BENT CHIPS from 28 to 116

Water from sand/gravel at 88' to 156'

Static level 21' below casing top which is 2' above GL

Pumping level 28' when pumping at 300 gpm for 2 hr(s)

Permanent pump installed at 105' on 11/20/2023, with a capacity of 320 gpm

Remarks: Driller's Estimated Well Yied 900 gpm

Location source: Global Positioning System verified

Permit Date: March 10, 2023

Permit #: 0599-FY2023

COMPANY Tracy A McConnel

FARM Vilage of Greenview

DATE DRILLED January 4, 2024

NO. 5

ELEVATION '

COUNTY NO. 21875

LOCATION

LATITUDE 40.097397

LONGITUDE -89.744533

COUNTY Menard

API# 1212921875 00

14-19N-6W