

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	3
clay yellow	3	6
sand fine to med	6	24
clay silty gray	24	41
sand fine to med	41	52
sand med to coarse w/ some fine gravel	52	67

Total Depth

67

Casing: 5" PVC SDR 21 from -2' to 63'

5" SCREEN from 63' to 167'

Screen: 4' of 5" diameter 20 slot

Grout: BENSEAL from 0 to 53

Water from sand/gravel at 18' to 67'

Static level 18' below casing top which is 2' above GL

Pumping level 21' when pumping at 35 gpm for 1 hr(s)

Permanent pump installed at 40' on 1/11/2024, with a capacity of 35 gpm

Remarks: Driller's Estimated Well Yield 35 gpm

Owner Address: 24365 Edwards St Greenvview, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date:

Permit #: 129-001-2024

COMPANY Greenfield, Edward K.

FARM Zeck, Tanner

DATE DRILLED January 11, 2024

NO. 1

ELEVATION 811' GL

COUNTY NO. 21876

LOCATION

LATITUDE 40.111194

LONGITUDE -89.764167

COUNTY Menard

API# 1212921876 00

10-19N-6W