

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	70
clay till w/boulders	70	120
silty sand	120	124
fine/medium sand	124	130

Total Depth **130**

Casing: 10" STD. WALL from 0' to 120'

10" SS SCREEN from 120' to 130'

Screen: 10' of 10" diameter 0.03 slot

Grout: NEAT CEMENT from 0 to 20

WB-50 from 28 to 60

WB-35 from 60 to 145

Water from fine/medium sand at 124' to 130'

Static level 21' below casing top which is 2' above GL

Pumping level 103' when pumping at 27 gpm for 24 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Remarks: est. well yld 27 gpm, no pump installed

Address of well:

Location source: Location from the driller

Permit Date:

Permit #:

COMPANY Brotcke Engineering

FARM Village of Farmersville

DATE DRILLED July 6, 2000

NO. 7

ELEVATION 0'

COUNTY NO. 23964

LOCATION

LATITUDE 39.385430

LONGITUDE -89.686765

COUNTY Montgomery

API# 1213523964 00

19-11N-5W