

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
top soil	0	1
brown clay	1	2
limestone	2	50
dolomite	50	123
dry sandstone	123	153
sandstone	153	230

Total Depth **230**

Casing: 6" STEEL #19 from -1' to 63'

Grout: CEMENT from 6 to 63

Water from sandstone at 153' to 230'

Static level 125' below casing top which is 1' above GL

Pumping level 160' when pumping at 0 gpm for 2 hr(s)

Permanent pump installed at 160' on 12/19/1990, with a capacity of 0 gpm

Owner Address: 9065 Hedge Rd. Byron, IL

Location source: Location from permit

Permit Date: November 2, 1990

Permit #:

COMPANY Olson, Robert C

FARM Markley, Richard

DATE DRILLED November 30, 1990

NO.

ELEVATION 0'

COUNTY NO. 23383

LOCATION

LATITUDE 42.144668

LONGITUDE -89.281747

COUNTY Ogle

API# 1214123383 00

25-25N-10E