

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	12
brown limestone	12	60
cave	60	64
limestone	64	180
sandstone	180	260

Total Depth **260**

Casing: 5" ASTM 53 from 0' to 156'

Grout: CEMENT from 0 to 156

Size hole below casing: 5"

Water from sandstone at 180' to 260'

Static level 60' below casing top which is 2' above GL

Pumping level 62' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 80' on 10/21/1994, with a capacity of 10 gpm

Owner Address: 8654 Rt. #2 Byron, IL

Location source: Location from permit

Permit Date: September 15, 1994

Permit #:

COMPANY Smeja, Robert B.

FARM Winkleman, Dean

DATE DRILLED October 15, 1994

NO.

ELEVATION 0'

COUNTY NO. 24021

LOCATION

LATITUDE 42.135564

LONGITUDE -89.245663

COUNTY Ogle

API# 1214124021 00

29-25N-11E