

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay w/stones	0	48
yellow lime	48	130
lime gray w/yellow stripes	130	245

Total Depth **245**

Casing: 6" PVC from -1' to 60'

Grout: NEET CEMENT from 0 to 60

Size hole below casing: 6"

Water from limestone at 130' to 245'

Static level 94' below casing top which is 1' above GL

Pumping level 115' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 125' on 3/6/1995, with a capacity of 18 gpm

Owner Address: 1000 Kennyhill Road Byron, IL

Address of well: 4700 Short Road

Location source: Location from permit

Permit Date: December 5, 1994

Permit #:

COMPANY Allabaugh, John H.

FARM Schultz, Charles J.

DATE DRILLED March 10, 1995

NO. 1

ELEVATION 0'

COUNTY NO. 24040

LOCATION

LATITUDE 42.168071

LONGITUDE -89.245597

COUNTY Ogle

API# 1214124040 00

17-25N-11E