

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
loam sandy	0	7
sand & gravel	7	35
limestone yellow	35	70
sandstone	70	140

Total Depth **140**

Casing: 5" ASTM 53 from 0' to 0'

Grout: CEMENT from 0 to 85

Size hole below casing: 5"

Water from lime - sandstone at 85' to 140'

Static level 30' below casing top which is 2' above GL

Pumping level 30' when pumping at 10 gpm for 0 hr(s)

Permanent pump installed at 60' on 4/20/1996, with a capacity of 10 gpm

Owner Address: 3113 10th St. Rockford, IL

Address of well: Walden Rd. Bryon, IL Bryon IL

Add'l loc info: Lot: #15 Subdivision: Walden Valley

Location source: Location from permit

Permit Date: November 8, 1995 **Permit #:** 141-95-149

COMPANY Smeja, Robert B.

FARM Lapp, Roger

DATE DRILLED February 15, 1996 **NO.** 1

ELEVATION 0' **COUNTY NO.** 24509

LOCATION

LATITUDE 42.108892 **LONGITUDE** -89.230718

COUNTY Ogle **API#** 1214124509 00 **4-24N-11E**