

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown clay	1	16
limestone	16	115
dolomite	115	200
limestone	200	204
dolomite	204	215

Total Depth

215

Casing: 5" .258 BLACK ASTM A53B from 0' to 80'

Grout: PORTLAND CEMENT from 0 to 80

Water from rock at 190' to 215'

Static level 30' below casing top which is 1' above GL

Pumping level 31' when pumping at 10 gpm for 6 hr(s)

Permanent pump installed at 0' on 7/21/1998, with a capacity of 0 gpm

Address of well: RR Adeline Rd.

Location source: Location from permit

Permit Date: June 25, 1998

Permit #: 141-062-98

COMPANY Martin, Lawrence

FARM Hundertmark, John

DATE DRILLED July 10, 1998

NO.

ELEVATION 0'

COUNTY NO. 24563

LOCATION

LATITUDE 42.175344

LONGITUDE -89.495853

COUNTY Ogle

API# 1214124563 00

7-25N-9E