

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
fill	0	1
topsoil	1	2
limestone	2	98
dolomite	98	109
sandstone	109	117
limestone	117	138
sandstone	138	265

Total Depth **265**

Casing: 5" .258 BLACK ASTM A53B from 0' to 80'

Grout: PORTLAND CEMENT from 0 to 80

Water from rock at 168' to 265'

Static level 80' below casing top which is 1' above GL

Pumping level 84' when pumping at 10 gpm for 6 hr(s)

Permanent pump installed at 0' on 2/23/1999, with a capacity of 0 gpm

Owner Address: 208 S. Third St. Byron, IL

Address of well: 4398 E. Falcon Byron, IL Byron IL

Add'l loc info: Lot: 22 Subdivision: Cascoi Crest

Location source: Location from permit

Permit Date: February 4, 1999

Permit #: 141-025-99

COMPANY Bull, Jack D.

FARM Adler, Sean

DATE DRILLED February 17, 1999

NO.

ELEVATION 0'

COUNTY NO. 24679

LOCATION

LATITUDE 42.148346

LONGITUDE -89.252809

COUNTY Ogle

API# 1214124679 00

20-25N-11E