

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	9
yellow & gray	9	87
gray limestone	87	120
shale	120	140
sandstone dirty	140	155
white sandstone	155	260
orange sandstone	260	290
white sandstone	290	345
white & orange sandstone	345	480
white limestone	480	510

Total Depth **510**

Casing: 6" SA53B from 0' to 171'

Grout: CEMENT from 1 to 171

Water from sandstone at 147' to '

Static level 147' below casing top which is 1' above GL

Pumping level 210' when pumping at 54 gpm for 6 hr(s)

Permanent pump installed at 0' on 6/8/2000, with a capacity of 0 gpm

Owner Address: Stronghold Residence Hall 4015 Lincolnway Suite E
Sterling, IL

Address of well: Oregon, IL Oregon IL

Add'l loc info: Subdivision: Stronghold

Location source: Location from permit

Permit Date: March 29, 2000

Permit #:

COMPANY Martin, Jonas Willard

FARM Blackhawk Presbyterian

DATE DRILLED April 24, 2000

NO.

ELEVATION 0'

COUNTY NO. 24973

LOCATION

LATITUDE 42.047778

LONGITUDE -89.345552

COUNTY Ogle

API# 1214124973 00

28-24N-10E