

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
yellow clay	0	12
yellow lime	12	75
gray lime	75	105
tan & gray lime	105	165
tan lime	165	235
hard sandstone	235	285

Total Depth **285**

Casing: 6" ASTM A53B from 0' to 84'

Grout: BENTONITE from 0 to 84

Water from hard sandstone at 235' to 285'

Static level 33' below casing top which is 1' above GL

Pumping level 285' when pumping at 50 gpm for 2 hr(s)

Permanent pump installed at 90' on 12/1/2000, with a capacity of 12 gpm

Remarks: driller's est. well yield 50 gpm

Owner Address: 4004 S. Unity Rd. Polo, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 13, 2000

Permit #:

COMPANY Dresden, Edward L.

FARM Kersten, Larry

DATE DRILLED December 1, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 24986

LOCATION

LATITUDE 41.958518

LONGITUDE -89.600354

COUNTY Ogle

API# 1214124986 00

29-23N-8E