

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
brown limestone	1	29
gray dolomite	29	47
brown limestone	47	68
gray dolomite	68	77
St. Peter	77	225

Total Depth

225

Casing: 5" ASTM A53A STEEL from 0' to 125'

Grout: PORTLAND from 0 to 125

Water from St. Peter at 100' to 225'

Static level 50' below casing top which is 1' above GL

Pumping level 54' when pumping at 6 gpm for 10 hr(s)

Permanent pump installed at 0' on 1/30/2002, with a capacity of 0 gpm

Owner Address: 6230 Skinner Rd. Byron, IL

Address of well: same as above

Location source: Location from permit

Permit Date: January 21, 2002

Permit #:

COMPANY Jack Bull Well & Septic

FARM Vacsaess, Ryan

DATE DRILLED January 23, 2002

NO.

ELEVATION 0'

COUNTY NO. 25232

LOCATION

LATITUDE 42.142434

LONGITUDE -89.214144

COUNTY Ogle

API# 1214125232 00

27-25N-11E