

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sandy clay & stones	0	15
clay & stones	15	165
sand & gravel	165	175
sandy clay	175	210
fine sand	210	225
sandstone	225	340

Total Depth **340**

Casing: 6" ASTM A53B STEEL from 0' to 227'

Grout: BENTONITE 3 BAGS from to

Water from sandstone at 225' to 340'

Static level 15' below casing top which is 2' above GL

Pumping level 50' when pumping at 50 gpm for 2 hr(s)

Permanent pump installed at 150' on 6/19/2007, with a capacity of 22 gpm

Remarks: bathhouse, Driller's Est 200 gpm

Owner Address: 415 N. 2nd St. St. Charles, IL

Address of well: 3998 Knoll Rd. Chana, IL Chana IL

Boy Scout Camp

Location source: Location from permit

Permit Date: May 22, 2007

Permit #: 141-041-07

COMPANY Stone, Guy D.

FARM Three Fires Council, B.S.A.

DATE DRILLED June 1, 2007

NO.

ELEVATION '

COUNTY NO. 25808

LOCATION

LATITUDE 41.960778

LONGITUDE -89.178000

COUNTY Ogle

API# 1214125808 00

25-23N-11E