

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	10
soft limestone	10	45
limestone	45	170
Glenwood	170	210
sandstone	210	255

Total Depth

255

Casing: 6" ASTM A53A STEEL WELD from -1' to 62'

Grout: CEMENT from 0 to 62

Water from sandstone at 210' to 255'

Static level 110' below casing top which is 1' above GL

Pumping level 135' when pumping at 15 gpm for 3 hr(s)

Permanent pump installed at 160' on 6/27/2007, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 2732 N. Stephanie Dr. Lindenwood, IL

Address of well: 2nd & Main St. Kings, IL Kings IL

Location source: Location from permit

Permit Date: April 23, 2007

Permit #: 141-028-07

COMPANY Stone, Guy D.

FARM Beaird, Greg

DATE DRILLED June 14, 2007

NO.

ELEVATION

COUNTY NO. 25890

LOCATION

LATITUDE 42.003194

LONGITUDE -89.105444

COUNTY Ogle

API# 1214125890 00

27-41N-1E