

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	10
soft clay	10	34
soft limestone	34	39
yellow limestone	39	40
gray limestone	40	57
shale-limestone sandstone	57	120
sandstone	120	220

Total Depth

Casing: 6" WT STEEL from -1' to 22'
 6" PVC from 22' to 141'

Grout: BENTONITE from 0 to 140

Static level 120' below casing top which is 1' above GL

Pumping level 125' when pumping at 25 gpm for 4 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Owner Address: 120 1/2 N. 4th St. Oregon, IL

Address of well: Butternut Rd

Location source: Location from permit

Permit Date: July 9, 1992

Permit #: 141-92-077

COMPANY Martin, Jonas

FARM Jackson, Ken

DATE DRILLED July 14, 1992

NO. 1

ELEVATION '

COUNTY NO. 25911

LOCATION

LATITUDE 41.962670

LONGITUDE -89.421407

COUNTY Ogle

API# 1214125911 00

23-23N-9E