

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay & stones	0	5
broken limestone & clay	5	10
limestone	10	30
blue shale	30	95
hard green shale	95	170
limestone gp	170	325

Total Depth

325

Casing: 6" STEEL WELD from -1' to 125'

Grout: BENTONITE from 0 to 125

Water from limestone at 260' to 325'

Static level 130' below casing top which is 1' above GL

Pumping level 180' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 205' on 9/25/2022, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 20 gpm

Owner Address: 207 N Locust St Forresteron, IL

Address of well: 12502 N Springfield Rd Baileyville, IL 61007
Baileyville IL

Location source: Global Positioning System verified

Permit Date: August 19, 2022

Permit #: 141-016-2022

COMPANY Rosenquist, Robert G.

FARM Akins, Bill

DATE DRILLED September 23, 2022

NO.

ELEVATION

'

COUNTY NO. 26351

LOCATION

LATITUDE 42.193167

LONGITUDE -89.556500

COUNTY Ogle

API# 1214126351 00

3-25N-8E