

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black dirt	0	2
brown sand	2	10
gray clay	10	30
brown sand & gravel dry	30	41
limestone brown	41	120
gray limestone	120	209
brown limestone crevice	209	212
dolomite	212	225

Total Depth

225

Casing: 6" ASTM A 53B from 1' to 51'

Grout: QUICK GROUT from 0 to 51

Water from limestone at 100' to 225'

Static level 55' below casing top which is 1' above GL

Pumping level 60' when pumping at 12 gpm for 2 hr(s)

Permanent pump installed at 80' on 1/8/2024, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 50 gpm

Owner Address: 307 W Main St Monroe Center, IL

Address of well: 309 W Main St Monroe Center, IL Monroe Center IL

Location source: Global Positioning System verified

Permit Date: January 2, 2024

Permit #: 141-001-2024

COMPANY Martin, Charles

FARM TR Union Church

DATE DRILLED January 5, 2024

NO. 2402

ELEVATION '

COUNTY NO. 26370

LOCATION

LATITUDE 42.098111

LONGITUDE -89.003250

COUNTY Ogle

API# 1214126370 00

21-42N-2E