

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
soft yellow clay	0	18
coarse yellow sand & gravel & clay mix	18	21
hard blue clay	21	40
hard brown clay	40	53
soft blue clay	53	61
hard blue clay	61	76

Total Depth

76

Casing: 6" SDR 21 PLASTIC from 0' to 11'
 36" CONCRETE TILE from 11' to 76'

Water from clay mix at 20' to 22'

Static level 20' below casing top which is 2' above GL

Pumping level 60' when pumping at 10 gpm for 1 hr(s)

Permanent pump installed at 0' on 1/3/1997, with a capacity of 0 gpm

Owner Address: 16309 W. Garrett Rd. Glasford, IL

Location source: Location from permit

Permit Date: November 21, 1996

Permit #:

COMPANY Kuntz, John

FARM May, James E. & Michelle

DATE DRILLED December 17, 1996

NO. 1

ELEVATION 0'

COUNTY NO. 25126

LOCATION

LATITUDE 40.595974

LONGITUDE -89.853818

COUNTY Peoria

API# 1214325126 00

7-7N-6E