

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
sand brown	0	36
sand brown fine & rocks	36	54
sand medium med and rocks	54	84

Total Depth **84**

Casing: 4" A53B STEEL from -1' to 81'

3.75" SS SCREEN from 81' to 84'

Screen: 3' of 3.75" diameter 0.04 slot

Grout: BENSEAL from to

Water from sand brown at 54' to 84'

Static level 49' below casing top which is 1' above GL

Pumping level 50' when pumping at 31 gpm for 2 hr(s)

Permanent pump installed at 63' on 3/28/2016, with a capacity of 10 gpm

Remarks: Driller's Estimated Well Yield 40 gpm

Owner Address: 15123 N. Old Galena Rd. Chillicothe, IL

Address of well: same as above

Location source: Global Positioning System verified

Permit Date: July 7, 2015

Permit #: 143-025-15

COMPANY Hofstetter, Ralph W.

FARM Stephens, Mark

DATE DRILLED October 13, 2015

NO.

ELEVATION 516' GL

COUNTY NO. 35601

LOCATION

LATITUDE 40.866779

LONGITUDE -89.550232

COUNTY Peoria

API# 1214335601 00

3-10N-8E